



REGISTRO CONTROL AGUA DE CONSUMO

DIPUTACIÓN DE CUENCA

MUNICIPIO: MOTA DEL CUERVO

MES: JUNIO 2025

DÍA	HORA	CLORO LIBRE (ppm)	TURBIDEZ	pH	HIPOCLORITO APORTADO	OBSERVACIONES				
							OLOR	COLOR	SABOR	TURBIDEZ
2	9:15	0,14	0,52	7,7		Se aumenta inyección	OK	OK	OK	OK
4	14:00	0,38	0,56	7,7			OK	OK	OK	OK
11	14:20	0,47	0,62	7,3			OK	OK	OK	OK
13	14:15	0,67	0,66	7,3			OK	OK	OK	OK
16	14:16	0,68	0,6	7,3			OK	OK	OK	OK
18	13:00	0,68	0,64	7,3			OK	OK	OK	OK
24	13:20	0,51	0,58	7,3			OK	OK	OK	OK
30	14:05	0,45	0,6	7,3			OK	OK	OK	OK

Concentración Cloro libre residual:0,2-1 ppm

pH:6,5-9,5