



REGISTRO CONTROL AGUA DE CONSUMO

DIPUTACIÓN DE CUENCA

MUNICIPIO: MOTA DEL CUERVO

MES: MAYO 2025

DÍA	HORA	CLORO LIBRE (ppm)	TURBIDEZ	pH	HIPOCLORITO APORTADO	OBSERVACIONES				
							OLOR	COLOR	SABOR	TURBIDEZ
6	9:15	0,39	0,52	7,7			OK	OK	OK	OK
9	14:00	0,46	0,56	7,7			OK	OK	OK	OK
12	14:20	0,4	0,62	7,3			OK	OK	OK	OK
14	14:15	0,6	0,66	7,3			OK	OK	OK	OK
19	14:16	0,53	0,6	7,3			OK	OK	OK	OK
21	13:00	0,61	0,64	7,3			OK	OK	OK	OK
26	13:20	0,5	0,58	7,3			OK	OK	OK	OK
30	14:05	0,52	0,6	7,3			OK	OK	OK	OK

Concentración Cloro libre residual:0,2-1 ppm

pH:6,5-9,5