



REGISTRO CONTROL AGUA DE CONSUMO
DIPUTACIÓN DE CUENCA

MUNICIPIO: MOTA DEL CUERVO
MES: SEPTIEMBRE 2025

DÍA	HORA	CLORO LIBRE (ppm)	TURBIDEZ	pH	HIPOCLORITO APORTADO	OBSERVACIONES				
							OLOR	COLOR	SABOR	TURBIDEZ
1	9:15	0,64	0,52	7,7			OK	OK	OK	OK
5	14:00	0,64	0,56	7,7			OK	OK	OK	OK
10	14:20	0,68	0,62	7,3			OK	OK	OK	OK
15	14:15	0,55	0,66	7,3			OK	OK	OK	OK
19	10:00	0,5	0,54	7,3			OK	OK	OK	OK
22	10:20	0,45	0,55	7,3			OK	OK	OK	OK
24	14:16	0,48	0,6	7,3			OK	OK	OK	OK
29	13:00	0,42	0,64	7,3			OK	OK	OK	OK

Concentración Cloro libre residual:0,2-1 ppm pH:6,5-9,5